NON-CIL 1R ITEMS

SYSTEM:

Electrical

REV & DATE: J, 12-19-97

SUBSYSTEM:

Feedthru Receptacles

DCN & DATE:

Per NSTS 22206, certain failure modes of the following items in subsystem 3.11 (feedthru Receptacles) meet the criteria to be designated "Non-CIL 1R". Rationale for Retention is not required.

FMEA Item Codes: 3.11.1.3 and 3.11.5.3.

CRITICAL ITEMS LIST (CIL)

SYSTEM:

Electrical

SUBSYSTEM: REV & DATE: LHZ forward Feedthru Receptacle J, 12-19-97

FUNCTIONAL CRIT: PHASE(S): HAZARD REF:

1R E.01

DCN & DATE:

ANALYSTS:

J. Kent/A. Oser

FAILURE MODE:

High Resistance (Within False Dry Band)

FAILURE EFFECT:

Loss of mission and vehicle/crew due to fire/explosion caused by LH2 flowing out of

vent valve.

TIME TO EFFECT:

Seconds

FAILURE CAUSE(S):

Faulty Pin

REDUNDANCY SCREENS:

Screen A: PASS Screen B: N/A Screen C: PASS

FUNCTIONAL DESCRIPTION: The cryogenic feedthru connector provides the electrical connection between the temperature and level sensors in the LM2 tank and the external harmesses.

FMEA ITEM PART NO. PART NAME OTY EFFECTIVITY CODE(S) 3.11.5.3 81L2-2 LWT-54 & Up 1 feedthru Receptacle (302A01 J1, J2)

Item meets criteria for Non-CIL 1R. Rationale for Retention is not required. REMARKS: